



METROPOLITAN GOVERNMENT OF NASHVILLE AND DAVIDSON COUNTY

To: All Prospective Offerors

From: David Friedlander
Contract Specialist

Date: April 27, 2010

Subject: Amendment # 2, ITB #52693DF

Acknowledge receipt of the amendment with your offer. Failure to do so may subject the prospective offerors to disqualification. This amendment forms part of the above-mentioned procurement and clarifies the previously issued documents.

Vendor Question:

The HVAC DDC control system was to also control some lighting circuits. Can we get a definition on the number of circuits to be controlled?

Yes, there are approximately 17 lighting circuits in three different electrical panels.